

# **Heat Transfer: Heat Exchangers, Steam Generators Cooling Towers**

**...just the figures for those who got the B&W version...**

**by D. James Benton**



Copyright © 2018-2021 by D. James Benton, all rights reserved.





**Typical Tube Bundle and Tube Sheet**



**Typical Spray and Splash Bars**








	A	B	C	D	E
1	<b>crossflow example</b>				
2	symbol	units	hot	cold	
3	U	W/m <sup>2</sup> °C	150		
4	Cp	kJ/kg°C	4.0	1.8	
5	m	kg/s	100	500	
6	Tin	°C	50	15	
7	Tout	°C	20	39.0	
8	q	kW		12,000	
9	LMTD	°C		7.61	
10	P	-		0.686	
11	R	-		0.800	
12	symbol	units	unmix	1mix	mixed
13	F	-	0.667	0.352	0.183
14	UA	kW/°C	2362	4481	8622
15	A	m <sup>2</sup>	15.7	29.9	57.5
16	<b>user inputs in blue</b>				
17	<b>calculations in orange</b>				

Crossflow Heat Exchanger Test with Uncertainty



measurement	units	average	points	std.dev.	bias	total unc.	sensitivity	units	contrib
Thot,in	°C	51.25	30	0.82	0.14	0.34	-148.7	kW/°C <sup>2</sup>	-50
Thot,out	°C	20.85	30	0.79	0.14	0.33	-330.6	kW/°C <sup>2</sup>	-108
Tcold,in	°C	15.95	30	0.65	0.14	0.28	197.8	kW/°C <sup>2</sup>	56
Tcold,out	°C	40.35	30	0.63	0.14	0.28	281.6	kW/°C <sup>2</sup>	78
m,hot	kg/s	98.84	30	1.93%	2.0%	2.1%	55.41	kWs/kg/°C	116
m,cold	kg/s	497.55	30	1.62%	2.0%	2.1%	-6.156	kWs/kg/°C	-64
calculation	units	value							203
LMTD	°C	7.50							8.4%
q,hot	kW	12,019							
q,cold	kW	12,140							
q,avg	kW	12,080							
mCp,hot	kW/°C	395.358							
mCp,cold	kW/°C	497.549							
R	-	0.795							
P,hot	-	0.684							
P,cold	-	0.691							
F,hot	-	0.674							
F,cold	-	0.660							
UA,hot	kW/°C	2377							
UA,cold	kW/°C	2451							
UA,avg	kW/°C	2414							
UA_design	kW/°C	2362							
ΔUA	-	2.2%							




















Performance Prediction




	A	B	C	D	E	F	G	H	I
1	<b>Feed Water Heater Example</b>								
2	INPUTS			CALCULATIONS					
3	feed water inlet	units		feed water inlet	units				
4	flow	lbm/hr	350,000	enthalpy	BTU/lbm	345.9			
5	pressure	psia	2250	feed water outlet					
6	temperature	°F	370	enthalpy	BTU/lbm	431.4			
7	feed water outlet			extraction					
8	pressure	psia	2200	saturation	°F	467.0			
9	temperature	°F	450	TTD	°F	17.0			
10	extraction			superheat	°F	58.0			
11	pressure	psia	500	enthalpy	BTU/lbm	1249.7			
12	temperature	°F	525	flow	lbm/hr	33,382			
13	drain			drain					
14	temperature	°F	380	DCA	°F	10.0			
15				enthalpy	BTU/lbm	354.0	U	A	area
16	heat trans. zone	Gx10 <sup>6</sup>	UA	zone color	units	ΔT	BTU/hr/ft <sup>2</sup> /°F	ft <sup>2</sup>	frac
17	de-superhtng	1.5	0.035	yellow	°F	42.4	100	354	23%
18	condensing	25.2	0.537	green	°F	46.9	600	895	58%
19	subcooling	3.2	0.089	cyan	°F	36.0	300	295	19%
20	process line		0.661	calculations		T		1544	
21	point 1	0	525	sat. vapor	BTU/lbm	1204.7			
22	point 2	1.5	467	sat. liquid	BTU/lbm	449.5			
23	point 3	26.7	467	desup. exit temp	°F	446.0			
24	point 4	29.9	380	cond. exit temp.	°F	378.5			





### Feed Water Heater Test with Uncertainty



measurement	units	average	points	std.dev.	bias	total unc.	sensitivity	units	contrib
Tfw,in	°F	371.5	30	0.63	0.14	0.28	-213.021	BTU/hr/°F/°F	-58.74
Tfw,out	°F	451.3	30	0.47	0.14	0.23	19948.34	BTU/hr/°F/°F	4530
Textract	°F	524.8	30	0.58	0.14	0.26	-964.167	BTU/hr/°F/°F	-250.7
Tdrain	°F	380.3	30	0.71	0.14	0.30	-3949.15	BTU/hr/°F/°F	-1191
Pfw,in	psia	2248	30	0.93%	0.75%	0.01	-11.601	BTU/hr/°F/psia	-0.096
Pfw,out	psia	2201	30	0.86%	0.75%	0.01	5.699626	BTU/hr/°F/psia	0.046
Pextract	psia	499	30	0.74%	0.75%	0.8%	-2995.15	BTU/hr/°F/psia	-23.86
flow_fw	lbm/hr	337,213	30	0.98%	2.0%	2.0%	1.966478	BTU/hr/°F/lbm/hr	0.04
calculation	units	value							4691
hfw,in	BTU/lbm	347.5							5.2%
hfw,out	BTU/lbm	432.8							
hextract	BTU/lbm	1249.6							
hg	BTU/lbm	1204.7							
hf	BTU/lbm	449.3							
hdrain	BTU/lbm	354.3							
flow_extract	lbm/hr	32,123							
Qdesuper	BTU/hr	1.4E+06							
Qconds	BTU/hr	2.4E+07							
Qsubcool	BTU/hr	3.1E+06							
Tsat	°F	466.8							
TTD	°F	15.5							
DCA	°F	8.8							
Tfw,desup	°F	447.3							
Tfw,subco	°F	380.0							
LMTD_desup	°F	40.7							
LMTD_cond	°F	45.1							
LMTD_subc	°F	34.1							
UA_desup	BTU/hr/°F	3.5E+04							
UA_conds	BTU/hr/°F	5.4E+05							
UA_subco	BTU/hr/°F	9.0E+04							
UA_total	BTU/hr/°F	6.6E+05							

calculate sensitivities
























## Performance Prediction

	A	B	C	D	E	F
1	<b>Moisture Separator Reheater Example</b>					
2	INPUTS	units	value	CALCS.	units	value
3	HP Tubes			LP Tubes		
4	Flow	lbm/hr	<b>100,000</b>	Tinlet	°F	<b>443.6</b>
5	Pinlet	psia	<b>834.5</b>	Toutlet	°F	<b>438.7</b>
6	Hinlet	BTU/lbm	<b>1295.6</b>	Houtlet	BTU/lbm	<b>1054.9</b>
7	Poutlet	psia	<b>824.2</b>	Shell Side		
8	Xoutlet	%	<b>97%</b>	Tinlet	°F	<b>370.8</b>
9	LP Tubes			Xinlet	%	<b>88.7%</b>
10	Flow	lbm/hr	<b>75,000</b>	Tchevr	°F	<b>369.2</b>
11	Pinlet	psia	<b>396.1</b>	Xchevr	%	<b>98.3%</b>
12	Hinlet	BTU/lbm	<b>1150.1</b>	Hchevr	BTU/lbm	<b>1181.7</b>
13	Poutlet	psia	<b>376.4</b>	Hmidl	BTU/lbm	<b>1196.0</b>
14	Xoutlet	%	<b>81%</b>	Tmidl	°F	<b>368.7</b>
15	Shell Side			Houtlet	BTU/lbm	<b>1219.4</b>
16	Flow	lbm/hr	<b>500,000</b>	Toutlet	°F	<b>385.8</b>
17	Pinlet	psia	<b>175.0</b>	superheat	°F	<b>17.6</b>
18	Hinlet	BTU/lbm	<b>1100.0</b>	LP Tubes		
19	chevrns	%	<b>85%</b>	Q	BTU/hr	<b>7.14E+06</b>
20	Pchevr	psia	<b>171.7</b>	LMTD	°F	<b>72.2</b>
21	Poutlet	psia	<b>169.4</b>	FUA	BTU/hr/°F	<b>9.90E+04</b>
22	CALCS.	units	value	HP Tubes		
23	HP Tubes			Q	BTU/hr	<b>1.17E+07</b>
24	Tinlet	°F	<b>596.0</b>	LMTD	°F	<b>63.7</b>
25	Toutlet	°F	<b>521.7</b>	FUA	BTU/hr/°F	<b>1.84E+05</b>
26	Houtlet	BTU/lbm	<b>1178.2</b>			

**Impact of Extraction Flow on Superheat****Impact of Extraction Flow on Required FUA**



E	 <p data-bbox="267 253 408 277">One-Pass Shell</p>	J	 <p data-bbox="703 269 823 293">Divided Flow</p>
F	 <p data-bbox="224 466 440 506">Two-Pass Shell with Longitudinal Baffle</p>	K	 <p data-bbox="682 529 866 553">Kettle-Type Reboiler</p>
G	 <p data-bbox="288 699 376 724">Split Flow</p>	X	 <p data-bbox="703 773 812 797">Cross Flow</p>
H	 <p data-bbox="256 928 419 953">Double Split Flow</p>		







	A	B	C	D
<b>1</b>	<b>TEMA E-Shell Example</b>			
2	symbol	units	tube	shell
3	U	W/m <sup>2</sup> °C	65	
4	Cp	kJ/kg°C	2.5	1.0
5	m	kg/s	1000	8000
6	T <sub>in</sub>	°C	250	50
7	T <sub>out</sub>	°C	100	96.9
8	q	kW	375,000	
9	mCp	kW/°C	2,500	8,000
10	R	-	0.313	
11	ε	-	0.750	
12	NTU	-	1.965	
13	UA	-	4913	
14	A	m <sup>2</sup>	75.6	
15	<b>user inputs in blue</b>			
16	<b>calculations in orange</b>			

TEMA E-Shell Heat Exchanger Test with Uncertainty



measurement	units	average	points	std.dev.	bias	total unc.	sensitivity	units	contrib
Thot,in	°C	247.61	30	2.11	0.14	0.80	-34.2	$\text{kW}/\text{°C}^2$	-27
Thot,out	°C	101.24	30	1.79	0.14	0.68	-59.4	$\text{kW}/\text{°C}^2$	-41
Tcold,in	°C	51.53	30	1.65	0.14	0.63	-115.0	$\text{kW}/\text{°C}^2$	-73
Tcold,out	°C	97.81	30	1.44	0.14	0.56	208.5	$\text{kW}/\text{°C}^2$	116
m_hot	kg/s	1000	30	1.93%	2.0%	2.1%	-2.17	$\text{kW}/\text{kg}/\text{°C}$	-46
m_cold	kg/s	8000	30	1.62%	2.0%	2.1%	0.889	$\text{kW}/\text{kg}/\text{°C}$	149
calculation	units	value							213
mCp_hot	$\text{kW}/\text{°C}$	2500							4.3%
mCp_cold	$\text{kW}/\text{°C}$	8000							
R	-	0.313							
q_hot	$\text{kW}$	365,925							
q_cold	$\text{kW}$	370,240							
q_avg	$\text{kW}$	368,083							
c_hot	-	0.746							
c_cold	-	0.755							
NTU_hot	-	1.932							
NTU_cold	-	2.018							
UA_hot	$\text{kW}/\text{°C}$	4829							
UA_cold	$\text{kW}/\text{°C}$	5044							
UA_avg	$\text{kW}/\text{°C}$	4937							
UA_design	$\text{kW}/\text{°C}$	4913							
$\Delta\text{UA}$	-	0.5%							
calculate sensitivities									



























	A	B	C	D
1	<b>Condensation on Horizontal Tubes in Crossflow</b>			
2	INPUTS	symbol	units	value
3	Steam Turbine Exhaust			
4	turbine annulus area	Aan	ft <sup>2</sup>	<b>72</b>
5	number of ends	Nan	-	<b>4</b>
6	Condenser Geometry			
7	tube length	L	ft	<b>40.0</b>
8	number of tubes	N	-	<b>12,000</b>
9	tube outside dia.	do	in	<b>1.125</b>
10	tube gauge	ga	-	<b>22</b>
11	tube wall conduct.	kw	BTU/hr/ft. <sup>2</sup> F	<b>9.32</b>
12	tube pitch	pitch	in	<b>1.125</b>
13	Steam			
14	steam flow	stm	lbm/hr	<b>2,500,000</b>
15	steam quality	x	-	<b>91%</b>
16	Cooling Water			
17	flow	Qccw	gpm	<b>240,000</b>
18	inlet temperature	Tccw,in	°F	<b>60</b>
19	SOLUTION			
20	backpressure	Psat	in.HgA	<b>1.84</b>


21	PROPERTIES	symbol	units	value
22	Cooling Water			
23	density	$\rho$	lbm/ft <sup>3</sup>	62.37
24	specific heat	Cp	BTU/lbm/°F	1.0004
25	viscosity	$\mu$	lbm/ft/hr	2.712
26	thermal cond.	k	BTU/hr/ft/°F	0.3423
27	Prandtl Number	Pr	-	7.93
28	Steam			
29	liquid density	$\rho_l$	lbm/ft <sup>3</sup>	62.01
30	vapor density	$\rho_g$	lbm/ft <sup>3</sup>	0.0027
31	latent heat	hfg	BTU/lbm	1037.6
32	liquid viscosity	$\mu_l$	lbm/ft/hr	1.678
33	liquid thermal cond.	kl	BTU/hr/ft/°F	0.3611
34	CALCULATIONS	symbol	units	value
35	Condenser Geometry			
36	tube wall thick.	wt	in	0.028
37	tube inside dia.	di	in	1.069
38	water flow area	Af	ft <sup>2</sup>	74.79
39	surface area	As	ft <sup>2</sup>	141,372
40	steam flow area	Ap	ft <sup>2</sup>	410.79

41	Cooling Water			
42	duty	duty	BTU/hr	2.358E+09
43	mass flow rate	mccw	lbm/hr	1.201E+08
44	outlet temperature	Tccw_out	°F	79.63
45	velocity inside tubes	ut	ft/sec	7.15
46	tube side Reynolds	Re,t	-	52,729
47	tube side Nusselt	Nu,t	-	315
48	tube side ht. tr. coef.	ht	BTU/hr/ft/°F	1212
49	tube wall ht. tr. coef.	hw	BTU/hr/ft/°F	3894
50	Steam			
51	operating pressure	Psat	psia	0.9046
52	saturation temp.	Tsat	°F	98.38
53	exit specific volume	1/ρan	ft <sup>3</sup> /lbm	332.5
54	annulus velocity	Van	ft/sec	802
55	log mean temp. diff.	LMTD	°F	27.4
56	required conductance	U	BTU/hr/°F	608.9
57	film Reynolds number	Re	-	2.874E+05









K	L	M	N	O	P	Q	R	S	T	U	V	W	X
CALCULATIONS													
CCW flow	duty	cond. density	cond. flow	LPTA exh. pres.	LPTB exh. pres.	LPTA exh. temp.	LPTB exh. temp.	LPTA exhaust quality	LPTB exhaust quality	shell A LMTD	shell B LMTD	shell A U	shell B U
gpm	BTU/hr	lbm/ft <sup>3</sup>	lbm/hr	in.HgA	in.HgA	Deg F	Deg F	-	-	Deg F	Deg F	BTU/hr/ft <sup>2</sup> F	BTU/hr/ft <sup>2</sup> F
457,219	3.018E+09	61.980	3,372,124	1.710	2.091	95.88	102.54	0.8612	0.8644	11.98	12.02	645.9	644.0
457,129	3.017E+09	61.980	3,374,448	1.715	2.087	95.98	102.48	0.8604	0.8635	12.08	11.95	640.3	647.1
457,268	3.018E+09	61.980	3,370,850	1.711	2.086	95.90	102.46	0.8615	0.8646	12.01	11.94	644.2	648.1
457,140	3.016E+09	61.980	3,374,185	1.712	2.082	95.93	102.41	0.8603	0.8634	12.06	11.91	641.5	649.6
457,148	3.016E+09	61.980	3,373,994	1.717	2.090	96.04	102.53	0.8604	0.8635	12.18	12.04	635.1	642.1
457,835	3.019E+09	61.981	3,361,398	1.718	2.091	96.05	102.55	0.8645	0.8676	12.21	12.08	633.9	640.6
458,209	3.023E+09	61.980	3,346,434	1.722	2.098	96.11	102.66	0.8694	0.8725	12.28	12.20	631.3	635.4
458,291	3.023E+09	61.980	3,344,267	1.725	2.101	96.17	102.71	0.8700	0.8732	12.32	12.24	629.0	633.1
457,369	3.017E+09	61.979	3,368,202	1.722	2.099	96.11	102.68	0.8620	0.8651	12.28	12.23	629.7	632.4
456,025	3.007E+09	61.979	3,402,518	1.725	2.098	96.19	102.66	0.8508	0.8538	12.37	12.21	623.6	631.6
456,384	3.010E+09	61.979	3,393,416	1.728	2.099	96.22	102.66	0.8538	0.8567	12.40	12.21	622.3	632.1
457,793	3.019E+09	61.979	3,357,203	1.733	2.107	96.32	102.80	0.8655	0.8686	12.50	12.36	619.2	626.3
458,271	3.021E+09	61.978	3,344,665	1.734	2.113	96.36	102.90	0.8698	0.8727	12.55	12.48	617.3	620.9












### Monte Carlo Heat Exchanger Uncertainty Model







Monte Carlo Heat Exchanger Uncertainty Model




Monte Carlo Heat Exchanger Uncertainty Model











	A	B	C	D
1	<b>crossflow example 11-211</b>			
2	symbol	units	hot	cold
3	U	W/m <sup>2</sup> °C	205	
4	Cp	kJ/kg°C	4.19	1.01
5	m	kg/s	5.25	2.39
6	T <sub>in</sub>	°C	65.0	15.0
7	T <sub>out</sub>	°C	62.9	34.5
8	q	kW	47.1	
9	LMTD	°C	38.52	
10	P	-	0.043	0.390
11	R	-	9.113	0.110
12	symbol	units	one mixed	
13	F-LMTD method			
14	F	-	0.995	
15	UA	kW/°C	1.23	
16	A	m <sup>2</sup>	5.98	
17	P-NTU method			
18	NTU	-	0.0558	0.509
19	UA	kW/°C	1.23	1.23
20	A	m <sup>2</sup>	5.98	5.98
21	<b>user inputs in blue</b>			
22	<b>calculations in orange</b>			
23	<b>linked cells in green</b>			

### Explicit FDM Convergence







### Implicit FDM Convergence





Cold Side Temperatures







Temperature Difference









Temperature Difference





Temperature Difference


















A	B	C	D	E	F	G	H	I
Single Pressure HRSG								
case	mC	mH	Pci	Pco	Tci	Tco	Thi	Tho
name	lb/hr	lb/hr	psia	psia	°F	°F	°F	°F
SH	300,000	3,000,000	1800	1750	621	1050	1100	986
EV	300,000	3,000,000	1800	1800	621	621	986	824
EC	300,000	3,000,000	1950	1800	120	616	824	641
J	K	L	M	N	O	P	Q	
Single Pressure HRSG								
Q	CpC	CpH	Rc	Rh	Pc	Ph	NTUc	
MBTU/hr	BTU/lb/°F	BTU/lb/°F	-	-	-	-	-	
108.86	0.846	0.319	0.27	3.77	0.896	0.237	####	
150.73	∞	0.310	∞	0.00	0.000	0.443	0.59	
164.13	1.103	0.299	0.37	2.71	0.704	0.260	1.69	
R	S	T	U	V	W	X		
NTUh	LMTD	F	UA	ΣQ	Th	Tc		
-	°F	-	MBTU/hr/°F	MBTU/hr	°F	°F		
0.91	158.50	0.78	0.69	0.00	1100	1050		
0.59	276.46	1.00	0.55	108.86	986	621		
0.60	341.30	0.90	0.48	259.58	824	616		
		total	1.71	423.71	641	120		
<b>user inputs in blue</b>								
calculations in orange								




Impact of Steam Flow



Impact of Steam Pressure







Impact of Gas Flow






Impact of Gas Temperature








Triple Pressure HRSG




Triple Pressure HRSG




























GT
HPSH4
RH3
HPSH3
RH2
DB
HPSH2
HPSH1
RH1
HPEV4
HPEV3
HPEV2
HPEV1
HPEC6
SCR

IPSH
HPEC5
HPEC4
LPSH
IPEV3
IPEV2
IPEV1
HPEC3
IPEC
HPEC2
HPEC1
LPEV3
LPEV2
LPEV1
LPEC4
LPEC3
LPEC2
LPEC1
STACK











































M19060.5FT  
14.696 BAROMETRIC (psia)

78.0 WET BULB (°F)  
20.0 RANGE (°F)







Crossflow Cooling Tower Demand Calculations

user inputs

**50** Twb

**120** Thw

**2.00** L/G

**1.38** KaY

calculations

83.2 Tcw


36.8 range



33.2 approach



						Tw				
Ta						120.0	120.0	120.0	120.0	120.0
50	102	113	117	119	119	92.6	107.7	114.5	117.5	118.9
50	78	97	108	113	117	81.7	95.2	104.3	110.6	114.7
50	70	86	97	105	111	74.7	87.1	96.2	103.2	108.5
50	65	79	89	98	104	69.8	81.1	89.9	96.9	102.6
50	62	74	83	91	98	66.0	76.4	84.7	91.7	97.4
						Hw				
Ha						119.7	119.7	119.7	119.7	119.7
20.3	75.2	99.7	110.7	115.7	117.9	59.6	87.2	103.7	112.2	116.3
20.3	42.0	66.9	87.2	101.0	109.4	45.6	63.7	80.1	93.9	104.2
20.3	34.3	50.5	66.8	81.8	94.2	38.4	52.1	65.3	77.7	88.9
20.3	30.3	42.3	55.0	67.5	79.3	33.9	44.9	55.8	66.4	76.6
20.3	27.8	37.2	47.5	57.9	68.2	30.8	39.9	49.1	58.3	67.3



SHAPE10.11F  
14.696 BAROMETRIC (psia)


78.0 WET BULB (°F)  
20.0 RANGE (°F)




































### HEAT AND MASS TRANSFER FOR A SINGLE DROP

$T_{wb}=65$ ,  $T_o=90$ ,  $V_a=10$











































Crossflow Fills






Counterflow Fills



















		NASA Glenn Properties												
					specific heat [kJ/kg/°C]					enthalpy [kJ/kg]				
		°K	°C	°F	N2	O2	CO2	H2O	Ar	N2	O2	CO2	H2O	Ar
ambient	275	2	35	1.04	0.92	0.82	1.86	0.52	-24	-21	-8961	-13466	-12	
	300	27	80	1.04	0.92	0.85	1.86	0.52	2	2	-8940	-13420	1	
	325	52	125	1.04	0.92	0.87	1.87	0.52	28	25	-8918	-13373	14	
HRSG gas	350	77	170	1.04	0.93	0.89	1.88	0.52	54	48	-8896	-13326	27	
	375	102	215	1.04	0.93	0.92	1.89	0.52	80	71	-8874	-13279	40	
	400	127	260	1.04	0.94	0.94	1.90	0.52	106	95	-8850	-13232	53	
	425	152	305	1.05	0.95	0.96	1.91	0.52	132	118	-8827	-13184	66	
	450	177	350	1.05	0.96	0.98	1.93	0.52	158	142	-8803	-13136	79	

	475	202	395	1.05	0.96	1.00	1.94	0.52	185	166	-8778	-13088	92
	500	227	440	1.06	0.97	1.01	1.96	0.52	211	190	-8753	-13039	105
	525	252	485	1.06	0.98	1.03	1.97	0.52	237	215	-8727	-12990	118
	550	277	530	1.06	0.99	1.05	1.99	0.52	264	239	-8701	-12940	131
	575	302	575	1.07	1.00	1.06	2.00	0.52	291	264	-8675	-12891	144
	600	327	620	1.07	1.00	1.08	2.02	0.52	317	289	-8648	-12840	157
	625	352	665	1.08	1.01	1.09	2.03	0.52	344	314	-8621	-12790	170
	650	377	710	1.09	1.02	1.10	2.05	0.52	372	339	-8594	-12739	183
	675	402	755	1.09	1.02	1.11	2.06	0.52	399	365	-8566	-12687	196
	700	427	800	1.10	1.03	1.13	2.08	0.52	426	391	-8538	-12636	209
GT exhaust	725	452	845	1.10	1.04	1.14	2.10	0.52	454	416	-8510	-12583	222
	750	477	890	1.11	1.04	1.15	2.12	0.52	481	443	-8481	-12531	235
	775	502	935	1.12	1.05	1.16	2.13	0.52	509	469	-8452	-12478	248
	800	527	980	1.12	1.05	1.17	2.15	0.52	537	495	-8423	-12424	261
	825	552	1025	1.13	1.06	1.18	2.17	0.52	565	521	-8394	-12370	274
	850	577	1070	1.13	1.06	1.19	2.18	0.52	593	548	-8364	-12316	287
	875	602	1115	1.14	1.07	1.20	2.20	0.52	622	575	-8334	-12261	300
	900	627	1160	1.15	1.07	1.20	2.22	0.52	650	601	-8304	-12206	313





**Inline Tube Bank**




**Staggered Tube Bundle**



**Various Tube Bundles**





**Finned Tubes**

